



OFFICE OF THE  
**BALURGHAT MUNICIPALITY**

SOVA MAJUMDER SARANI  
BALURGHAT : DAKSHIN DINAJPUR

PH. NO : 03522 - 255450 / 255680 / 256930 / 255649 / 256931 / 255655  
<<< FAX - 03522 - 255649 >>>

e-mail - [bmipality@gmail.com](mailto:bmipality@gmail.com)

website : [www.balurghatmunicipality.org](http://www.balurghatmunicipality.org)

Memo No:- 3450/PW(Elec)-3

Date:- 01/12/2025

NOTICE INVITING QUOTATIONS

Sealed quotations are hereby invited from the local contractors for "Electrification works of Muktyo Mancha in front of Suresh Ranjan Park under Balurghat Municipality" as per following specification & quantity. Quotation will be received by the undersigned upto 3.00 p.m. on or before 24.12.2025 on working days and will be opened on 24.12.2025 at 4.00 p.m. when the quotationers may remain present. Quotations must be accompanied with valid self attested copies of I.T., G.S.T., PAN and trade license should be enclosed with quotation. Rate to be quoted including all taxes. The undersigned reserves the right to cancel or accept any or all the quotations without assigning any reason.

Sl. No.	Description of item	Qty	unit
1	Supplying & fixing sheet steel Main switches on angle iron frame on wall 100/125 A 415V TPN with fuse on L&N (Havells make)	1	No.
2	Supply & fixing 415 V, 125A TPN on load front operated Changeover switch with sheet steel enclosure on angle iron frame on wall with nuts bolts etc. (Havells make)	1	No.
3	Supply & fixing 415V, 125A TPN SFU with sheet steel enclosure on angle iron frame on wall with nuts bolts etc incl. S&F 3 ns. DIN type HRC fuse as per rating. (Havells make)	1	No.
4	Supply & Fixing sheet steel metal (16 SWG) Iron Clad Busbar chambers on angle iron frame on wall, incl. earthing attachmenmt and painting as required- (As per Drawing no. 470 of PWD Specification Book May- 1991) 4 bars. 415V, 100/125A. Dimension of Al. Bars [ 85 mm long]- 4x25x5 mm; Dimension of Sheet Metal Box - 500x150mm.	1	No.
5	Supplying and fixing 240/415 V MCB of Breaking capacity 10kA & C characteristics on din rail of existing DBs and necessary connection 6-32A SP MCB (Make -Havells)	4	Nos.
6	Supplying and fixing MCB SS enclosure with IP-20/30 protection, powder coated provision for two pole MCB, concealed in wall after cutting the wall & mending good the damages to original finish incl. painting, connection & provision for earthing attachment. (2 Way)	4	Nos.
7	Supply & fixing 240/415 V MCB isolator on din rail of existing DBs and necessary connection 63A DP. (Legrand make)	1	No.
8	Supplying and fixing double-door Horizontal TPN MCB Distribution Board with IP-42/43 protection, concealed in wall after cutting the wall & mending good the damages to original finish incl. Inter connection with suitable size of copper wire and neutral link & provision for earthing attachment. 8 Way Enclosure (607717) Legrad make.	1	No.
9	Supply & Fixing 240 V, 6 A, 3 pin Modular type plug socket (Brand approved by EIC) with 6A Modular type switch, without plug top on 4 Module GI Modular type switch board with 3 Module top cover plate flushed in wall incl. S&F switch board and cover plate and making necy. connections with PVC Cu wire and earth continuity wire etc.	4	Nos.
10	Supply & Fixing 240 V, 16 A, 3 pin Modular type plug socket (Brand approved by EIC) with 16A Modular type switch, without plug top on 4 Module GI Modular type switch board with top cover plate incl. S&F switch board and cover plate and making necy. connections with PVC Cu wire and earth continuity wire etc.	4	Nos.
11	Supply & fixing 240V, 25 A, 3 pin Modular type plug socket with 20/25A Modular switch (Brand approved by EIC) type SP MCB (C-Curve) and 4 Module GI Modular type switch board with 4 Module top cover plate flushed in wall incl. S&F switch board and cover plate and making necy. connections with PVC Cu wire and earth continuity wire etc.	4	nos.
12	Distribution wiring in 2 x 22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire(Brand approved by EIC) in 20mm size PVC rigid conduit 'FR' (Precision make), with 1x22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire for ECC, to light/fan/call bell points with Piano Key type switchfixed on MS CRC sheet metal (16 SWG) switch board cum JB on wall complete with 2 no. suitable size "Ph & N" copper bar incl. bakelite/Perspex (wall matching color) top cover 3 mm thick and incl. 175mmx100mmx65mm inspection box, making earthing attachment, painting the MS box and mending good the damages to original finish. Average run 5 mtr	2	Points



13	Distribution wiring in 1.1 KV single core stranded 'FR' PVC insulated & unsheathed copper wire (Brand approved by EIC) in 20mm size PVC rigid conduit 'FR' (Precision make) incl. necy. fittings as required 2 x 36/0.3 (2.5 sqmm) + 1 x 22/0.3 (1.5 sqmm) ECC	20	Mtr.
14	Supply of 20 W LED Lamp, (Philips make, Base B22/B27, 2000 LM)	2	Nos.
15	Fixing only 20 W LED Lamp [PWD Schedule Page C-2, Item no. 11].	2	Nos.
16	Erection of 1 nos 3.25 mtr to 5.0 mtr. meter Steel Tubular pole in C.C Foundation 0.46 m * 0.46 m * 0.9 mtr depth of 1:3:6 cement concrete with hard jhama metal / stone chips including muffing of 0.3 m * 0.3 m * 0.3 m painting the pole with 2 coats of Aluminium paint over a coat red oxide.	2	Nos.
17	Supplying and Drawing 1.1 KV single core stranded 'FR' PVC insulated & unsheathed single core stranded copper wire (Brand approved by EIC) of the following sizes in the prelaid polythene pipe and by the prelaid GI fish wire and making necy. connection as required (a)3x22/0.3(1.5sqmm)	32	Mtr.
18	Supplying & fixing of 2 core 6 sqmm of 1.1 KV grade alluminium XLPE, PVC/ armoured LT cable (Mescab make/ Rezen make/ Juvas make)	60	Mtr.
19	Laying of one No. cable upto 35 sqmm in underground trench 460 mm wide x 760 mm average depth, with brick protection on the top of the cable with 8(eight) Nos. bricks per metre, including filling the space between the brick & cable and also the trench with shifted soil, leveling up and restoring surface duly rammed	50	Mtr.
20	Fixing only Flood light Fitting with suitable tie clamps and MS plate for mounting on Pole/Tower or similar structure	4	Nos.
21	Supply,delivaryof 1.1KV grade 4 Core x 25 sq.mm XLPE Insulated PVC sheathed Al armoured Cable (Polycab/ Gloster/Havells) as per IS- 7098	15	Mtr.
22	Earthing with 50 mm dia GI pipe 3.64 mm thick x 3.04 Mts. long and 1 x 4 SWG GI (Hot Dip) wire (4 Mts. long), 13 mm dia x 80 mm long GI bolts, double nuts, double washers incl. S & F 15 mm dia GI pipe protection (1 Mts. long) to be filled with bitumen partly under the ground level and partly above ground level driven to an average depth of 3.65 Mts. below the ground level as below: By ISI Mark- Medium GI pipe	1	No.
23	Supply & fixing of 18 mm thick size: 3ft X 7ft water proof Ply-wood board (with necessary fitings).	1	No.
24	Supply & installation of Tri Colour LED rope light Philips make (18mtr. Length) including adaptor.	2	Nos.

Chairman  
Balurghat Municipality

Date:-  
15/12/2025

Memo No:- 3450 /1(8)/PW(Elec)-3

Copy to:-

1. The District Magistrate, Dakshin Dinajpur, Balurghat.
2. The Sub Divisional Officer, Balurghat Sadar, Dakshin Dinajpur.
3. The District Information & Cultural Officer, Dakshin Dinajpur, Balurghat.
4. The Executive Engineer, P.W.D., Dakshin Dinajpur, Division, Balurghat.
5. The Executive Engineer, P.W.D. Electrical, Dakshin Dinajpur, Division, Balurghat.
6. The Divisional Manager WBSEDCL, Dakshin Dinajpur, (D) Division, Balurghat.
7. The Assistant Engineer, P.W.D., Balurghat Electrical Sub Division, Balurghat, Dakshin Dinajpur.
8. The Assistant Engineer, WBSEDCL, Balurghat Customer Care Centre, Balurghat, Dakshin Dinajpur

For information and wide publication through their Notice Board please.

Chairman  
Balurghat Municipalit

Date:- 19/12/2025

Memo No:- 3450 /2(09)/PW(Elec)-3

Copy to:-

1. Sri. Bipul Kanti Ghosh, MCIC, Balurghat Municipality.
2. The Executive Officer, Balurghat Municipality.
3. The Finance Officer, Balurghat Municipality.
4. The Assistant Engineer, Balurghat Municipality.
5. The Head Clerk, Balurghat Municipality.
6. The Accountant, Balurghat Municipality.
7. The Cashier, Balurghat Municipality.
8. Sri. Saumyadip Dey, S.A.E. Electrical (contractual), Balurghat Municipality.
9. Sri. D.Saha, In-charge receive section, Balurghat Municipality.

Chairman  
Balurghat Municipality